

Certificate of Compliance

Certificate: 70044209

Master Contract: 217664

Project: 70044209

Date Issued: August 31, 2015

Issued to: EMI Solutions Pvt.Ltd
No. 237-A5 Bommasandra Indl. Area
Hosur Road, Bangalore-560099,
INDIA.
Attention: Mr. P. R.Vijayan

*The products listed below are eligible to bear the CSA Mark shown
with adjacent indicator ▲*



Issued by: *Amarta Rakshit*
Amarta Rakshit

PRODUCTS

CLASS 2221 02 – AUDIO AND VIDEO EQUIPEMNT - Electromagnetic Interference (EMI) filters

Feed through capacitors, Type Y2, to be used in facility filters, 250Vac, 50/60 Hz, 1-phase, 40°C ambient with current rating as below:

Model	Current	Capacitance
EMIS / FTC1	0.5A – 30A	0.1 μ F - 1 μ F
EMIS / FTC2	5A - 100A	0.1 μ F – 2.2 μ F
EMIS / FTC3	5A - 300A	0.1 μ F - 5 μ F

CONDITION OF ACCEPTABILITY

Feed through are certified as components to be used in facility filters where suitability of the combination is to be determined by CSA Group.

APPLICABLE REQUIREMENTS

- | | |
|-----------------------|--|
| CSA C22.2 No 0- M91 | - General Requirements – Canadian Electrical Code, Part II |
| CSA C22.2 No. 0.4 -04 | - Bonding of Electrical Equipment |
| CSA C22.2 No. 8-13 | - Electromagnetic Interference (EMI) Filters |



Certificate: 70044209

Master Contract: 217664

Project: 70044209

Date Issued: August 31, 2015

Supplement to Certificate of Compliance

Certificate: 70044209

Master Contract: 217664

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70044209	August 31, 2015	Original Certification.